



# PUNE MUNICIPAL CORPORATION

## Parvati Water Works Laboratory

Date : 25/04/2024

Report ID : CH55

Report of Water Samples Collected as on 12/04/2024

Challan No : 1242500002 Challan Date : 12/04/2024 Amount (Rs.): 1620.0

मालकाचे नाव : BBS International School & Junior College

पुणे महानगरपालिका  
पर्वती जलकेंद्र पुणे ३  
जाचक क्र. - CH-55  
दिनांक - 25/04/2024


1) BBS International School & Junior College, Gate No-1078, Wagholi-Awhalwadi Road, Wagholi, Pune 412207  
Purified Water Sample

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	6.72	Between 6.5 To 8.5	No Relaxation	-
Turbidity	0.4	Max 1	Max 5	N.T.U
Total Hardness (as CaCO <sub>3</sub> )	10.0	Max 200	Max 600	PPM
Chlorides (as Cl)	9.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	20.0	Max 200	Max 600	PPM
Nitrate Nitrogen (as NO <sub>3</sub> )	0.5	Max 45	No relaxation	PPM
Nitrite Nitrogen (as NO <sub>2</sub> )	0.04	-	-	PPM
Coliform	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	Nil	0.2	-	PPM


Remark : सदरचा नमुना / नमुने मालकांनी स्वतः आणून दिला. उपरोक्त नमुना / नमुने हा प्रातिनिधिक असल्याचे गृहीत धरले आहे. सदरचा अहवाल हा वैयक्तिक माहितीसाठी असून, याचा वापर कुठल्याही प्रकारचा परवान्यासाठी केल्याने उद्भवणाऱ्या कायदेशीर बाबीस हे कार्यालय जबाबदार असणार नाही. तसेच नमुनांच्या उद्भवणाऱ्या पडताळा ह्या कार्यालयामार्फत केलेला नाही.

शेरा :

The Above Water Sample Is Potable as per IS:10500:2012

  
**PRINCIPAL**  
BBS International School & Junior Collage,  
Gat No. 1078, Wagholi; Tal - Haveli,  
Dist. Pune. 412207.

  
**DIRECTOR**  
H.B.P. Bhausaheb Govindrao Satav  
Educational And Development Foundation.

  
25/04/2024  
केमिस्ट  
पर्वती जलकेंद्र  
पुणे महानगरपालिका